

APPLICATION OF HARDWARE

INSTALL ALL FINISH HARDWARE FOR A COMPLETE INSTALLATION, PER MANUFACTURER'S INSTRUCTION AND SPECIFICATIONS. ROUGH HARDWARE: USE STANDARD TYPE, SIZE, QUALITY AND MANUFACTURE AS APPLICABLE TO THE SPECIFIC NEED AND AS APPROVED BY THE ARCHITECT.

FINALLY

DO ANY OTHER ROUGH OR FINISH WOODWORK REQUIRED TO COMPLETE THE CONSTRUCTION WHETHER OR NOT HERE SPECIFIED.

CABINET WORK

TO BE VERTICAL GRAIN 3/4" FIR PLYWOOD PANELING WITH DIMENSIONS AS SHOWN ON THE DRAWINGS. COUNTER TOPS AND 4" SPLASHES SHALL BE SELF EDGED FORMICA AS SELECTED.

PART 8 SHEET METAL

THE GENERAL REQUIREMENTS APPLY.

FLASHING

SHALL BE 26 GA. GI, UNLESS OTHERWISE INDICATED ON THE DRAWINGS.

FABRICATION AND INSTALLATION

ACCORDING TO THE BEST PRACTICE.

WORKMANSHIP

SHALL BE FORMED TO THE SHAPE AND DIMENSIONS SHOWN ON THE DRAWINGS OR IN CONFORMANCE WITH GOOD PRACTICE. ALL EXPOSED EDGES SHALL BE BEADED OR RETURNED. SHEET METAL SHALL BE FITTED CLOSELY AND NEATLY. SOLDER AS NEEDED AT MITERS AND OTHER PLACES FOR TIGHTNESS.

PART 9 GLAZING

THE GENERAL REQUIREMENTS APPLY.

GLASS SIZES

THE SIZES OF GLASS SHOWN ON THE DRAWINGS ARE APPROXIMATE AND THE ACTUAL SIZE IS TO BE DETERMINED ACCORDING TO THE JOB.

WINDOW GLASS

SHALL BE DSB OR AS SUPPLIED BY THE MANUFACTURER.

INSTALLATION

IF GLASS IS NOT SHOR SET, DO NOT SET GLASS UNTIL REBATES HAVE BEEN PRIMED AND PRIME IS DRY. ALL GLASS SHALL BE BEADED, BACK PUTTED, SECURED IN PLACE AND PUTTED UNDER STOPS. GLAZING CHANNELS MAY BE USED WITH THE ARCHITECT'S APPROVAL. SECURE GLASS AS PER MANUFACTURER'S DIRECTIONS.

MITERS

SELECT SHEET.

PART 10 ROOFING & SIDING

THE GENERAL REQUIREMENTS APPLY.

MATERIAL

SHALL BE AS FOR A "BARRETT" TYPE 15-YEAR ROOF NO. 215W WITH STREAM WASHED TOPPING AS PER MANUFACTURER'S SPECIFICATIONS.

PART 11 DRYWALL

THE GENERAL REQUIREMENTS APPLY.

MATERIAL

WALLBOARD: SHALL BE 5/8" TAPERED EDGE GY WALLBOARD AS MANUFACTURED BY USG. BACKING BLOCKS: SHALL BE 5/8" SHEETROCK GY AS MANUFACTURED BY USG. JOINT REINFORCING: SHALL BE PERFORMED TAPE JOINT SYSTEM. METAL EDGES: USE USG #400 MT AT EDGES MEETING ANOTHER MATERIAL WHERE A NEAT JOINT CANNOT BE MADE AND AROUND ALL PLACES WHERE EDGES ARE EXPOSED. MCB SHALL BE USG #101.

METHOD

SHALL BE IN STRICT ACCORD WITH USG CO. SPECIFICATIONS FOR 5/8" SYSTEM UNBACKED.

PART 12 PAINTING

MASTER SPECIFICATIONS

SHALL CONFORM TO THE MASTER SPECIFICATIONS OF THE ARCHITECTURAL SPECIFICATIONS MANUAL, 9TH EDITION, OF PRATT AND LAMBERT, INC., "FOR MOTELS". SPECIFICATIONS AND MATERIALS OF EQUAL QUALITY WILL BE ACCEPTED FROM THE CONTRACTOR WHEN PRESENTED IN WRITTEN FORM AND APPROVED BY THE ARCHITECT.

PART 13 FLOOR COVERINGS

MATERIALS AND METHODS FOR FLOOR COVERINGS

CLEAN CONCRETE SUBFLOOR AND APPLY SHEET VINYL OR EQUAL STANDARD GRADE ALL BATHS, KITCHENS, AND ENTRIES. HARDENED CONCRETE ALL STORAGE, NON-PUBLIC UTILITY AREAS AND CONFERENCE ROOM.

CLEANING

UPON COMPLETION OF THE WORK, THOROUGHLY CLEAN CONCRETE SUBFLOOR FOR CARPET INSTALLATION AND THOROUGHLY CLEAN AND POLISH VINYL FLOORS ACCORDING TO THE VARIOUS MANUFACTURER'S INSTRUCTIONS. ONE COAT EACH OF ARMSTRONG COMMERCIAL CLEANER AND WAX OR APPROVED EQUAL.

PART 14 BUILDING SPECIALTIES

THE GENERAL REQUIREMENTS APPLY.

BATHROOM ACCESSORIES

AS SHOWN ON THE DRAWINGS.

CLOSET ACCESSORIES

HEAVY DUTY WOOD ROD EACH CLOSET, AS REQUIRED.

APPLIANCES

TO BE SUPPLIED BY CONTRACTOR IN KITCHEN: 1. SINK - STAINLESS STEEL, SINGLE BOWL BY ELKAY BLWR-2522 WITH FK-201 ACCESSORY. 2. DISPOSAL - INSINKERATOR "SILVERSTAR" #107. 3. DISHWASHER - GE #SF700C. 4. REFRIGERATOR - G.E. COPPERSTONE #1B-314X. 5. RANGE AND OVEN G.E. #J486-B7 SELF CLEANING, COPPERSTONE. 6. RANGE HOOD - "TRADEWIND", COPPER. 7. BATH FANS - EQUAL TO MIONE MODEL 8810. 8. BATH EQUIPMENT - CHROME TOILET PAPER HOLDER, CHROME SOAP DISH AND GRAB BAR, MEDICINE CABINET, SHOWER CURTAIN ROD AND FOUR 24" CHROME TOWEL BARS PER BATH BY HALLMACK INC.

MAILBOXES AND DIRECTORY UNITS AND BUZZER SYSTEM, DOOR NUMBERS, ETC.

SKYLIGHTS AS SHOWN ON DRAWINGS.